



April 7, 2017

To: Jim Smith, Director of Buildings and Ground

From: Rick Brynildson, Health and Safety Facilitator
Lakes Country Service Cooperative

Re: Lead in Water Testing Results Probstfield Elementary School

At your request, Rick Brynildson of Lakes Country Service Cooperative's Health and Safety Department sampled fifty-two water fixtures in Probstfield Elementary School and had each sample tested for lead content.

First draw samples in 8 oz. bottles were taken March 10, 2017 from the drinking water sources identified by the district to be tested. The bottles were capped, labeled and sent to the lab for analysis. DHIA Laboratories in Sauk Centre, Minnesota is certified by the Minnesota Department of Health (#027-145-378).

Results

Please find the laboratory report enclosed. The Environmental Protection Agency action level for lead in drinking water is 20 parts per billion (micrograms per liter, ug/l). When fixtures meet or exceed this level, action must be taken to reduce the lead content.

In Probstfield Elementary no water sources exceeded the 20 parts per billion limit.

Lead in Water testing is recommended every five years.

If you have any questions, please give me a call at 218-737-6555.